



ACCESS AUDIT CHECKLIST: Sheet 5 of 10

Block: Vertical Movement and Internal Level Change. Date of survey: September 2019

E – VERTICAL MOVEMENT AND INTERNAL LEVEL CHANGE

Consider each question from the perspective of each type of disability:

- **Wheelchair**
- **Ambulant**
- **Dexterity**
- **Visual**
- **Auditory**
- **Comprehension**

Tick the Y or N column as appropriate and add notes if necessary

A mark in the 'N' column indicates that the element should be given consideration in the school's Accessibility Plan.

	Y	N	Notes
E01. Is the location of any step/stairs/ramp clearly indicated by use of sign/colour/contrast/texture fighting?	Y		
E02. Does any step/stairs/ramp have a handrail to to one/both side(s)	Y		
E03. Is any level change clearly lit?	Y		
E04. Is the pitch (risers & treads) of step/stairs or any ramp consistent, and are nosings clearly identifiable?	Y		
E05. If there are landings are they large enough to permit passing and turning manoeuvres, and are they provided in any long flight?	Y		
E06. Is any short rise within a single storey ramped; if so is the ramped surface indicated, and is it slip-resistant?			N/A
E07. Are all ramp gradients easily negotiated? [Range length 3m max = 1 in 12, 6m max = 1 in 26, 10m max = 1 in 20]	Y		
E08. If a permanent ramp cannot be provided (perhaps a listed Building) can a moveable ramp be made available?			N/A
E09. Are steps available as an alternative to any ramp or ramped surface?	Y		
E10. Where level change is less than a full storey in height is a power-operated system appropriate? (Platform Lift/Stairlift/Lift - see 11, 12 & 13)? (delete)			N/A